

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management)
Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE [BS 7671: 2018+A2:2022 as amended]

FT/EIC 4158000001187

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Details

Client	Let 2	Installation	Let 2
Address	21 Yarm Road Stockton on Tees	Address	Flat 6/46 Hartington Road Stockton on Tees
Postcode	TS183NJ	Postcode	TS181HE

Details of the Installation

Description of premises Domestic Commercial Industrial Date of original installation

Installation is New Addition Alteration Records Available Yes No RCD Risk assessment attached

Description of the installation

Flat dwelling

Extent of the installation covered by this certificate

new consumer unit

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate

n/a

Declaration for Design, Construction, Inspection and Testing (for sole person responsibility)

I being the person responsible for design, construction, inspection and the test of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to except for the departures, if any, listed below. The extent of liability of the signatory or the signatories is limited to work described in Section 2 as subject of this certificate.

For the DESIGN / CONSTRUCTION / INSPECTION & TEST of the installation:

Company	Peter Lever Electrical	Position	Installer/Inspector
Inspector Name	Peter Lever	Date	<input type="text" value="10/11/2023"/>
Address	45 Ripon Way Middlesbrough TS6 9NE	Scheme No.	<input type="text" value="11881"/> Branch No. <input type="text" value="N/A"/>
Signature			Peter Lever

Reviewed By

Reviewed By Date

Reviewed By
Signature

Peter Lever

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than years

**ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]**

FT/EIC 4158000001187

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S TN-C-S TT Other If Other please specify

Number & Type of live conductors AC DC No. of phases 1 No. of wires 2

Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)

Nominal voltage, U/U₀ ⁽¹⁾ V Nominal frequency, f⁽¹⁾ Hz Confirmation of polarity

Prospective fault current, I_{pf} ⁽²⁾ kA External loop impedance, Z_a ⁽²⁾ Ω

Supply Protective Device BS (EN) Type Rated Current A

No. of Additional Supplies

Particulars of Installation at the Origin

Details of installation Earth Electrode (where applicable)		Type (e.g. rod(s), tape etc)	Means of Earthing	
Location	<input type="text"/>	Electrode resistance to earth	<input type="text"/> Ω	Distributors facility <input checked="" type="checkbox"/> Installation Earth Electrode <input type="checkbox"/>
				Maximum Demand (load) <input type="text" value="50"/> Amps <input type="checkbox"/> KVA <input type="checkbox"/>
Main Protective Conductors		Material	csa	(✓) or Value
Earthing Conductor	<input type="text" value="Copper"/>	<input type="text" value="10"/>	mm ²	Continuity Verified <input type="checkbox"/> <input type="text"/> Ω Connection Verified <input checked="" type="checkbox"/> <input type="text"/> Ω
Protective Bonding Conductor	<input type="text" value="Copper"/>	<input type="text" value="10"/>	mm ²	Continuity Verified <input checked="" type="checkbox"/> <input type="text"/> Ω Connection Verified <input type="checkbox"/> <input type="text"/> Ω
Main Supply Conductor		Material	csa	(connection / continuity) (✓) or Value
Main Switch Location	<input type="text" value="flat 6"/>	<input type="text" value="Copper"/>	<input type="text" value="16"/> mm ²	Water installation <input checked="" type="checkbox"/> <input type="text"/> Ω To structural steel <input type="checkbox"/> <input type="text"/> Ω
				Gas installation pipes <input type="checkbox"/> <input type="text"/> Ω To lightning protection <input type="checkbox"/> <input type="text"/> Ω
				Oil installation pipes <input type="checkbox"/> <input type="text"/> Ω Other <input type="checkbox"/> <input type="text"/> Ω
Fuse/device rating or setting	<input type="text" value="Switch"/>	A	Voltage rating <input type="text" value="230"/> V	BS(EN) <input type="text" value="60947-3"/> No. of Poles <input type="text" value="2"/> Current Rating <input type="text" value="100"/> A
If RCD main switch:	Rated residual operating current I _{Δn}	<input type="text" value="N/A"/> mA	Rated time delay <input type="text" value="N/A"/> ms	Measured operating trip time <input type="text" value="n/a"/> ms

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

satisfactory

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory		<input checked="" type="checkbox"/>	Indicates the inspection is not applicable to a particular item		<input type="checkbox" value="N/A"/>
1.0	Condition of consumer's intake equipment (visual inspection only)	<input checked="" type="checkbox"/>	8.0	Circuits (Distribution and Final)	<input checked="" type="checkbox"/>
2.0	Parallel or switched alternative sources of supply	<input type="checkbox" value="N/A"/>	9.0	Isolation and switching	<input checked="" type="checkbox"/>
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	<input checked="" type="checkbox"/>	10.0	Current-using equipment (permanently connected)	<input checked="" type="checkbox"/>
4.0	Basic Protection	<input checked="" type="checkbox"/>	11.0	Identification and notices	<input checked="" type="checkbox"/>
5.0	Protective measure other than ADS	<input checked="" type="checkbox"/>	12.0	Location(s) containing a bath or shower	<input type="checkbox" value="N/A"/>
6.0	Additional protection	<input checked="" type="checkbox"/>	13.0	Other special installations or locations	<input type="checkbox" value="N/A"/>
7.0	Distribution equipment	<input checked="" type="checkbox"/>	14.0	Prosumer's low voltage electrical installation(s)	<input checked="" type="checkbox"/>

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) schedules of circuit details and test results are attached

Inspector's Name: Signature
Date:

ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details

FT/EIC 4158000001187

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations

BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	Let 2	Installation Address	Let 2, Flat 6/46 Hartington Road, Stockton on Tees
Client Address	21 Yarm Road Stockton on Tees	Postcode	TS181HE
Client Postcode	TS183NJ		
Distribution board details - Complete in every case SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input checked="" type="checkbox"/> T3+ <input type="checkbox"/> N/A <input type="checkbox"/> Location flat 6 Designation DB 1 No. of ways 10		Complete only if the distribution board is not connected directly to the origin of the installation Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text"/> No. of phases 1 BS(EN) <input type="text"/> Type <input type="text"/> Rating <input type="text"/> A Nominal voltage <input type="text"/> V RCD BS(EN) <input type="text"/> Type <input type="text"/> A Rating <input type="text"/> 30 Δn mA	

SCHEDULE OF CIRCUIT DETAILS

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **Q** Other

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.

t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)

[: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.]

§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details

FT/EIC 4158000001187

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations

BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	Let 2	Installation Address	Let 2, Flat 6/46 Hartington Road, Stockton on Tees
Client Address	21 Yarm Road Stockton on Tees	Postcode	TS181HE
Client Postcode	TS183NJ		

SCHEDULE OF CIRCUIT DETAILS

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **Q** Other

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes

^t Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)

Where a 13 SPD is installed to protect sensitive equipment, see Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.

§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CERTIFICATE - Test Results

FT/EIC 4158000001187

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations

BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	Let 2	Installation Address	Let 2, Flat 6/46 Hartington Road, Stockton on Tees
Client Address	21 Yarm Road Stockton on Tees	Client Postcode	TS183NJ
		Installation Postcode	TS181HE
Distribution board details - Complete in every case			
Location			
Designation	DB 2	Complete only if the distribution board is not connected directly to the origin of the installation	
No. of ways	2	<input type="checkbox"/> Supply polarity confirmed	<input type="checkbox"/> Phase sequence confirmed
No. of phases	1	SPD: <input type="checkbox"/> Operational status confirmed	<input type="checkbox"/> Not applicable
Z_{db}	Ω	Operating at I _{Δn}	ms
I _{pf}	kA	No. of poles	Time delay (if applicable)

TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing Not Specified To Not Specified

Date(s) live testing Not Specified To Not Specified

Test instrument serial number(s)

Test instrument serial number(s)

Loop impedance insulation resistance Continuity RCD E/Electrode

Tested by: Name (capital letters) _____ Signature _____

Position Date Not Specified

For more information, contact the Office of the Vice President for Research and the Office of the Vice President for Student Affairs.